



PROPANE TANKS DOCUMENT SUBMITTAL CHECKLIST

Mechanical or Plumbing:

- Gas type.
- Isometric of piping layout (including location of regulators).
- Longest run of gas pipe (from source to farthest outlet).
- Pipe type, size(s) and gas pressures.
- Appliance(s) BTUH rating.
- Gas table used for sizing.

Building:

- Propane tanks require anchoring details.

Site plan required.

NOTE: A reference note indicating the specific sizing chart from FBC Fuel Gas 8th Edition (2023) or NFPA58 can be added to the piping isometric to save uploading the sizing chart.

Code Reference:

FBC Building 8th Edition (2023) Section 107.3.5

FBC Plumbing 8th Edition (2023)

FBC Fuel Gas 8th Edition (2023) Fuel Gas.

This document is intended to be a guide and may not contain all requirements needed to obtain permits and approval from Manatee County.

Development Review
1112 Manatee Ave. W 3rd Floor
Bradenton, FL 34205
Phone: (941) 748-4501
www.mymanatee.org